



[7590-01-P]

NUCLEAR REGULATORY COMMISSION

[NRC-2015-0220]

Seismic Design Classification for Nuclear Power Plants

AGENCY: Nuclear Regulatory Commission.

ACTION: Draft regulatory guide; request for comment.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is issuing for public comment draft regulatory guide (DG), DG-1315, "Seismic Design Classification for Nuclear Power Plants." The DG describes a method that the NRC staff considers acceptable for use in identifying and classifying those features of light-water-reactor (LWR) nuclear power plants that must be designed to withstand the effects of the safe-shutdown earthquake (SSE). DG-1315 is proposed revision 5 of Regulatory Guide (RG) 1.29.

DATES: Submit comments by **[INSERT DATE: 60 DAYS FROM THE DATE OF PUBLICATION IN THE *FEDERAL REGISTER*]**. Comments received after this date will be considered if it is practical to do so, but the NRC is able to ensure consideration only for comments received on or before this date. Although a time limit is given, comments and suggestions in connection with items for inclusion in guides currently being developed or improvements in all published guides are encouraged at any time.

ADDRESSES: You may submit comments by any of the following methods (unless this document describes a different method for submitting comments on a specified subject):

- **Federal Rulemaking Web site:** Go to <http://www.regulations.gov> and search for Docket ID **NRC-2015-0220**. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; e-mail: Carol.Gallagher@nrc.gov. For technical questions, contact the individuals listed in the FOR FURTHER INFORMATION CONTACT section of this document.

- **Mail comments to:** Cindy Bladey, Office of Administration, Mail Stop: OWFN-12H08, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

For additional direction on accessing information and submitting comments, see “Obtaining Information and Submitting Comments” in the **SUPPLEMENTARY INFORMATION** section of this document.

FOR FURTHER INFORMATION CONTACT: Yiu Law, Office of New Reactors, telephone: 301-415-0523, e-mail: Yiu.Law@nrc.gov or Edward O’Donnell, Office of Nuclear Regulatory Research, telephone: 301-415-3317, e-mail: Edward.ODonnell@nrc.gov. Both are staff of the U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments.

A. Obtaining Information.

Please refer to Docket ID **NRC-2015-0220** when contacting the NRC about the availability of information regarding this document. You may obtain publically-available information related to this document by the following methods:

- **Federal Rulemaking Web site:** Go to <http://www.regulations.gov> and search for Docket ID **NRC-2015-0220**.

- **NRC's Agencywide Documents Access and Management System (ADAMS):**

You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "[ADAMS Public Documents](#)" and then select "[Begin Web-based ADAMS Search](#)." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr.resource@nrc.gov. The DG is electronically available in ADAMS under Accession No. ML15061A048.

- **NRC's PDR:** You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

B. Submitting Comments.

Please include Docket ID **NRC-2015-0220** in the subject line of your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <http://www.regulations.gov> as well as enters the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submissions. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment into

ADAMS.

II. Additional Information.

The NRC is issuing for public comment a DG in the NRC's "Regulatory Guide" series. This series was developed to describe and make available to the public such information as methods that are acceptable to the NRC staff for implementing specific parts of the NRC's regulations, techniques that the staff uses in evaluating specific issues or postulated events, and data that the staff needs in its review of applications for permits and licenses.

The DG, entitled, "Seismic Design Classification for Nuclear Power Plants," is temporarily identified by its task number, DG-1315. DG-1315 is proposed revision 5 of RG 1.29. The guide describes a method that the staff of the NRC considers acceptable for use in identifying and classifying those features of LWR nuclear power plants that must be designed to withstand the effects of the SSE.

This DG does not present new regulatory requirements, but is intended to clarify content in Section C, "Staff Regulatory Guidance," by (1) addition of a reference to the definition of the reactor coolant pressure boundary in section 50.2 of Title 10 of the *Code of Federal Regulations* (CFR), and (2) a reorganization of systems and subsystems to add clarity to the staff guidance. It also adds a reference to a related international standard, and it was reformatted to align with current program guidance for regulatory guides.

III. Backfitting and Issue Finality.

DG-1315 describes a method that the staff of the NRC considers acceptable for use in identifying and classifying those features of LWR nuclear power plants that must be designed to withstand the effects of the SSE. Issuance of this DG, if finalized, would not constitute

backfitting as defined in 10 CFR 50.109 (the Backfit Rule) and would not otherwise be inconsistent with the issue finality provisions in 10 CFR part 52. As discussed in the “Implementation” section of this DG, the NRC has no current intention to impose this guided, if finalized, on holders of current operating licenses or combined licenses.

This DG may be applied to applications for operating licenses, combined licenses, early site permits, and certified design rules docketed by the NRC as of the date of issuance of the final regulatory guide, as well as future applications submitted after the issuance of the regulatory guide. Such action would not constitute backfitting as defined in the Backfit Rule or be otherwise inconsistent with the applicable issue finality provision in 10 CFR part 52, inasmuch as such applicants or potential applicants are not within the scope of entities protected by the Backfit Rule or the relevant issue finality provisions in part 52.

Dated at Rockville, Maryland, this 14th day of September, 2015.

For the Nuclear Regulatory Commission.

/RA/

Thomas H. Boyce, Chief,
Regulatory Guidance and Generic Issues Branch,
Division of Engineering,
Office of Nuclear Regulatory Research.
[FR Doc. 2015-23365 Filed: 9/16/2015 08:45 am;
Publication Date: 9/17/2015]