



NUCLEAR REGULATORY COMMISSION

[NRC-2025-0061]

Monthly Notice; Applications and Amendments to Facility Operating Licenses and Combined Licenses Involving No Significant Hazards Considerations

AGENCY: Nuclear Regulatory Commission.

ACTION: Monthly notice.

SUMMARY: Pursuant to section 189a.(2) of the Atomic Energy Act of 1954, as amended (the Act), the U.S. Nuclear Regulatory Commission (NRC) is publishing this regular monthly notice. The Act requires the Commission to publish notice of any amendments issued, or proposed to be issued, and grants the Commission the authority to issue and make immediately effective any amendment to an operating license or combined license, as applicable, upon a determination by the Commission that such amendment involves no significant hazards consideration (NSHC), notwithstanding the pendency before the Commission of a request for a hearing from any person.

DATES: Comments must be filed by **[INSERT DATE 30 DAYS AFTER DATE OF PUBLICATION IN THE *FEDERAL REGISTER*]**. A request for a hearing or petitions for leave to intervene must be filed by **[INSERT DATE 60 DAYS AFTER DATE OF PUBLICATION IN THE *FEDERAL REGISTER*]**. This monthly notice includes all amendments issued, or proposed to be issued, from January 31, 2025, to February 27, 2025. The last monthly notice was published on February 18, 2025.

ADDRESSES: You may submit comments by any of the following methods; however, the NRC encourages electronic comment submission through the Federal rulemaking website.

- *Federal rulemaking website:* Go to <https://www.regulations.gov> and search for Docket ID NRC-2025-0061. Address questions about Docket IDs in Regulations.gov to Bridget Curran; telephone: 301-415-1003; email: Bridget.Curran@nrc.gov. For

technical questions, contact the individual listed in the “For Further Information Contact” section of this document.

- *Mail comments to:* Office of Administration, Mail Stop: TWFN-7-A60M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, ATTN: Program Management, Announcements and Editing Staff.

For additional direction on obtaining information and submitting comments, see “Obtaining Information and Submitting Comments” in the SUPPLEMENTARY INFORMATION section of this document.

FOR FURTHER INFORMATION CONTACT: Kathleen Entz, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-2464; email: Kathleen.Entz@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID NRC-2025-0061, facility name, unit number(s), docket number(s), application date, and subject when contacting the NRC about the availability of information for this action. You may obtain publicly available information related to this action by any of the following methods:

- *Federal Rulemaking Website:* Go to <https://www.regulations.gov> and search for Docket ID NRC-2025-0061.

- *NRC’s Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1-800-397-4209, at 301-415-4737, or by email to PDR.Resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document.

- *NRC's PDR*: The PDR, where you may examine and order copies of publicly available documents, is open by appointment. To make an appointment to visit the PDR, please send an email to PDR.Resource@nrc.gov or call 1-800-397-4209 or 301-415-4737, between 8 a.m. and 4 p.m. eastern time (ET), Monday through Friday, except Federal holidays.

B. Submitting Comments

The NRC encourages electronic comment submission through the Federal Rulemaking Website (<https://www.regulations.gov>). Please include Docket ID NRC-2025-0061, facility name, unit number(s), docket number(s), application date, and subject, in your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <https://www.regulations.gov> as well as enter the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. Notice of Consideration of Issuance of Amendments to Facility Operating Licenses and Combined Licenses and Proposed No Significant Hazards Consideration Determination

For the facility-specific amendment requests shown in this notice, the Commission finds that the licensees' analyses provided, consistent with section 50.91 of title 10 of the *Code of Federal Regulations* (10 CFR) "Notice for public comment; State consultation," are sufficient to support the proposed determinations that these

amendment requests involve NSHC. Under the Commission's regulations in 10 CFR 50.92, operation of the facilities in accordance with the proposed amendments would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety.

The Commission is seeking public comments on these proposed determinations. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determinations.

Normally, the Commission will not issue the amendments until the expiration of 60 days after the date of publication of this notice. The Commission may issue any of these license amendments before expiration of the 60-day period provided that its final determination is that the amendment involves NSHC. In addition, the Commission may issue any of these amendments prior to the expiration of the 30-day comment period if circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example in derating or shutdown of the facility. If the Commission takes action on any of these amendments prior to the expiration of either the comment period or the notice period, it will publish in the *Federal Register* a notice of issuance. If the Commission makes a final NSHC determination for any of these amendments, any hearing will take place after issuance. The Commission expects that the need to take action on any amendment before 60 days have elapsed will occur very infrequently.

A. Opportunity to Request a Hearing and Petition for Leave to Intervene

Within 60 days after the date of publication of this notice, any person (petitioner) whose interest may be affected by any of these actions may file a request for a hearing and petition for leave to intervene (petition) with respect to that action. Petitions shall be filed in accordance with the Commission's "Agency Rules of Practice and Procedure" in 10 CFR part 2. Interested persons should consult a current copy of 10 CFR 2.309. If a

petition is filed, the Commission or a presiding officer will rule on the petition and, if appropriate, a notice of a hearing will be issued.

Petitions must be filed no later than 60 days from the date of publication of this notice in accordance with the filing instructions in the “Electronic Submissions (E-Filing)” section of this document. Petitions and motions for leave to file new or amended contentions that are filed after the deadline will not be entertained absent a determination by the presiding officer that the filing demonstrates good cause by satisfying the three factors in 10 CFR 2.309(c)(1)(i) through (iii).

If a hearing is requested, and the Commission has not made a final determination on the issue of no significant hazards consideration, the Commission will make a final determination on the issue of no significant hazards consideration, which will serve to establish when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, then any hearing held would take place before the issuance of the amendment unless the Commission finds an imminent danger to the health or safety of the public, in which case it will issue an appropriate order or rule under 10 CFR part 2.

A State, local governmental body, Federally recognized Indian Tribe, or designated agency thereof, may submit a petition to the Commission to participate as a party under 10 CFR 2.309(h) no later than 60 days from the date of publication of this notice. Alternatively, a State, local governmental body, Federally recognized Indian Tribe, or agency thereof may participate as a non-party under 10 CFR 2.315(c).

For information about filing a petition and about participation by a person not a party under 10 CFR 2.315, see ADAMS Accession No. ML20340A053 (<https://adamswebsearch2.nrc.gov/webSearch2/main.jsp?AccessionNumber=ML20340A053>) and on the NRC’s public website at

<https://www.nrc.gov/about-nrc/regulatory/adjudicatory/hearing.html#participate>.

B. Electronic Submissions (E-Filing)

All documents filed in NRC adjudicatory proceedings, including documents filed by an interested State, local governmental body, Federally recognized Indian Tribe, or designated agency thereof that requests to participate under 10 CFR 2.315(c), must be filed in accordance with 10 CFR 2.302. The E-Filing process requires participants to submit and serve all adjudicatory documents over the internet, or in some cases, to mail copies on electronic storage media, unless an exemption permitting an alternative filing method, as further discussed, is granted. Detailed guidance on electronic submissions is located in the “Guidance for Electronic Submissions to the NRC” (ADAMS Accession No. ML13031A056) and on the NRC’s public website at <https://www.nrc.gov/site-help/e-submittals.html>.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by email at Hearing.Docket@nrc.gov, or by telephone at 301-415-1677, to (1) request a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign submissions and access the E-Filing system for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a petition or other adjudicatory document (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC’s public website at <https://www.nrc.gov/site-help/e-submittals/getting-started.html>. After a digital ID certificate is obtained and a docket created, the participant must submit adjudicatory documents in Portable Document Format. Guidance on submissions is available on the NRC’s public website at <https://www.nrc.gov/site-help/electronic-sub-ref-mat.html>. A filing is considered complete at the time the document is submitted through

the NRC's E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. ET on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an email confirming receipt of the document. The E-Filing system also distributes an email that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the document on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before adjudicatory documents are filed to obtain access to the documents via the E-Filing system.

A person filing electronically using the NRC's adjudicatory E-Filing system may seek assistance by contacting the NRC's Electronic Filing Help Desk through the "Contact Us" link located on the NRC's public website at <https://www.nrc.gov/site-help/e-submittals.html>, by email to MSHD.Resource@nrc.gov, or by a toll-free call at 1-866-672-7640. The NRC Electronic Filing Help Desk is available between 9 a.m. and 6 p.m., ET, Monday through Friday, except Federal holidays.

Participants who believe that they have good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing stating why there is good cause for not filing electronically and requesting authorization to continue to submit documents in paper format. Such filings must be submitted in accordance with 10 CFR 2.302(b)-(d). Participants filing adjudicatory documents in this manner are responsible for serving their documents on all other participants. Participants granted an exemption under 10 CFR 2.302(g)(2) must still meet the electronic formatting requirement in 10 CFR 2.302(g)(1), unless the participant also seeks and is granted an exemption from 10 CFR 2.302(g)(1).

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket, which is publicly available at <https://adams.nrc.gov/ehd>, unless excluded pursuant to an order of the presiding officer. If you do not have an

NRC-issued digital ID certificate as previously described, click “cancel” when the link requests certificates and you will be automatically directed to the NRC’s electronic hearing docket where you will be able to access any publicly available documents in a particular hearing docket. Participants are requested not to include personal privacy information such as social security numbers, home addresses, or personal phone numbers in their filings unless an NRC regulation or other law requires submission of such information. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants should not include copyrighted materials in their submission.

The following table provides the plant name, docket number, date of application, ADAMS accession number, and location in the application of the licensees’ proposed NSHC determinations. For further details with respect to these license amendment applications, see the applications for amendment, which are available for public inspection in ADAMS. For additional direction on accessing information related to this document, see the “Obtaining Information and Submitting Comments” section of this document.

License Amendment Requests

Constellation Energy Generation, LLC; Braidwood Station, Units 1 and 2, Will County, IL; Byron Station, Unit Nos. 1 and 2, Ogle County, IL; Constellation Energy Generation, LLC; Calvert Cliffs Nuclear Power Plant, Units 1 and 2; Calvert County, MD; Constellation Energy Generation, LLC; R. E. Ginna Nuclear Power Plant; Wayne County, New York	
Docket Nos.	50-244, 50-317, 50-318, 50-454, 50-455, 50-456, 50-457
Application date	December 9, 2024
ADAMS Accession No.	ML24344A270
Location in Application of NSHC	Pages 3 - 5 of Attachment 1
Brief Description of Amendments	The amendments propose adoption of Technical Specification Task Force-475, Revision 1, "Control Rod Notch Testing Frequency and SRM [Supplier Relationship Management] Insert Control Rod Action."
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Jason Zorn, Associate General Counsel, Constellation Energy Generation, LLC 4300 Winfield Road Warrenville, IL 60555
NRC Project Manager, Telephone Number	Joel Wiebe, 301-415-6606

Constellation Energy Generation, LLC; Clinton Power Station, Unit No. 1; DeWitt County, IL; Constellation Energy Generation, LLC; LaSalle County Station, Units 1 and 2; LaSalle County, IL; Constellation Energy Generation, LLC; Limerick Generating Station, Units 1 and 2; Montgomery County, PA; Constellation Energy Generation, LLC; Peach Bottom Atomic Power Station, Units 2 and 3; York County, PA; Constellation FitzPatrick, LLC and Constellation Energy Generation, LLC; James A. FitzPatrick Nuclear Power Plant; Oswego County, NY; Nine Mile Point Nuclear Station, LLC and Constellation Energy Generation, LLC; Nine Mile Point Nuclear Station, Unit 2; Oswego County, NY	
Docket Nos.	50-461, 50-333, 50-373, 50-374, 50-352, 50-353, 50-410, 50-277, 50-278
Application date	January 31, 2025
ADAMS Accession No.	ML25031A384
Location in Application of NSHC	Pages 6 - 7 of Attachment 1
Brief Description of Amendments	The proposed amendments request adoption of Technical Specifications Task Force (TSTF) Traveler, TSTF-597, Revision 0, "Eliminate LCO [Limiting Condition for Operation] 3.0.3 Mode 2 Requirement." TSTF-597 revises LCO 3.0.3 to eliminate the requirement to enter Mode 2.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Jason Zorn, Associate General Counsel, Constellation Energy Generation, LLC, 101 Constitution Ave, NW, Suite 400 East, Washington, DC 20001
NRC Project Manager, Telephone Number	Scott Wall, 301-415-2855
Duke Energy Carolinas, LLC; Oconee Nuclear Station, Units 1, 2, and 3; Oconee County, SC	
Docket Nos.	50-269, 50-270, 50-287
Application date	January 30, 2025
ADAMS Accession No.	ML25030A354
Location in Application of NSHC	Pages 6-8 of the Enclosure
Brief Description of Amendments	The proposed amendments would revise Technical Specification 3.7.8, "Emergency Condenser Circulating Water (ECCW) System," Surveillance Requirement 3.7.8.3 to reflect variable Condenser Circulating Water inlet temperature limits.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Tracey Mitchell LeRoy, Deputy General Counsel, Duke Energy Corporation, 525 S. Tryon Street, Charlotte, NC 28202
NRC Project Manager, Telephone Number	Shawn Williams, 301-415-1009
National Institute of Standards and Technology (NIST), Center for Neutron Research Test Reactor, Montgomery County, Maryland	
Docket No.	50-184
Application date	December 19, 2024
ADAMS Accession No.	ML25014A396 (Package)
Location in Application of NSHC	Pages 1 - 2 of ML25014A398
Brief Description of Amendment	The proposed amendment would revise Table 3.2.2, "Reactor Safety System Channels Minimum

	Nuclear and Process Channels Required," and Table 4.2.2, "Surveillance Requirements for the Scram and Confinement Channels," in the technical specifications. Specifically, the proposed changes to Table 3.2.2 in Technical Specification 3.2.2, "Reactor Safety System Channels," would remove footnote 2, which allows one of the three flow scram channels to be bypassed for periods of maintenance during reactor operation. The proposed changes to Table 4.2.2 in Technical Specification 4.2.2, "Reactor Safety System Channels," would specify that both the inner and outer plenum flow scram channels need to be channel tested before reactor startup after a reactor shutdown of longer than 24 hours, or quarterly, and would require both scram channels to be calibrated annually.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Lauren Didiuk, Acting Chief Counsel - National Institute of Standards and Technology, 100 Bureau Dr., Gaithersburg, MD 20899
NRC Project Manager, Telephone Number	Justin Hudson, 301-287-0538
Pacific Gas and Electric Company; Diablo Canyon Nuclear Power Plant, Units 1 and 2; San Luis Obispo County, CA	
Docket Nos.	50-275, 50-323
Application date	December 24, 2024
ADAMS Accession No.	ML24359A003
Location in Application of NSHC	Pages 4 - 6 of the Enclosure
Brief Description of Amendments	The proposed amendments would revise Technical Specifications to adopt Technical Specifications Task Force (TSTF) Traveler TSTF- 541, "Add Exceptions to Surveillance Requirements for Valves and Dampers Locked in the Actuated Position," which is an approved change to the Standard Technical Specifications.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Jennifer Post, Esq., Pacific Gas and Electric Co., 77 Beale Street, Room 3065, Mail Code B30A, San Francisco, CA 94105
NRC Project Manager, Telephone Number	Samson Lee, 301-415-3168
Pacific Gas and Electric Company; Diablo Canyon Nuclear Power Plant, Units 1 and 2; San Luis Obispo County, CA	
Docket Nos.	50-275, 50-323
Application date	December 24, 2024
ADAMS Accession No.	ML24359A002
Location in Application of NSHC	Pages 6 - 7 of the Enclosure
Brief Description of Amendments	The proposed amendments would revise Technical Specifications (TSs) to adopt Technical Specifications Task Force (TSTF) Traveler TSTF- 505, "Provide Risk-Informed Extended Completion Times – RITSTF Initiative 4b," for TS 3.3.1,

	“Reactor Trip System (RTS) Instrumentation,” and TS 3.3.2, “Engineered Safety Feature Actuation System (ESFAS) Instrumentation.”
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Jennifer Post, Esq., Pacific Gas and Electric Co., 77 Beale Street, Room 3065, Mail Code B30A, San Francisco, CA 94105
NRC Project Manager, Telephone Number	Samson Lee, 301-415-3168
Pacific Gas and Electric Company; Diablo Canyon Nuclear Power Plant, Units 1 and 2; San Luis Obispo County, CA	
Docket Nos.	50-275, 50-323
Application date	December 31, 2024
ADAMS Accession No.	ML24366A127
Location in Application of NSHC	Pages 7 - 8 of the Enclosure
Brief Description of Amendments	The proposed amendments would revise technical specification completion times to be consistent with NUREG-1431, Revision 5, “Standard Technical Specifications Westinghouse Plants,” dated September 2021.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Jennifer Post, Esq., Pacific Gas and Electric Co., 77 Beale Street, Room 3065, Mail Code B30A, San Francisco, CA 94105
NRC Project Manager, Telephone Number	Samson Lee, 301-415-3168
Pacific Gas and Electric Company; Diablo Canyon Nuclear Power Plant, Units 1 and 2; San Luis Obispo County, CA	
Docket Nos.	50-275, 50-323
Application date	December 31, 2024
ADAMS Accession No.	ML24366A169
Location in Application of NSHC	Pages 20 - 21 of the Enclosure
Brief Description of Amendments	The proposed amendments would revise Technical Specifications 1.1, “Definitions” and 5.5, “Programs and Manuals,” to use the Analysis and Measurement Corporation online monitoring methodology.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Jennifer Post, Esq., Pacific Gas and Electric Co., 77 Beale Street, Room 3065, Mail Code B30A, San Francisco, CA 94105
NRC Project Manager, Telephone Number	Samson Lee, 301-415-3168
Southern Nuclear Operating Company, Inc.; Edwin I. Hatch Nuclear Plant, Units 1 and 2; Appling County, GA; Southern Nuclear Operating Company, Inc.; Joseph M. Farley Nuclear Plant, Units 1 and 2; Houston County, AL; Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 1 and 2; Burke County, GA; Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 3 and 4; Burke County, GA	
Docket Nos.	50-321, 50-348, 50-364, 50-366, 50-424, 50-425, 52-025, 52-026
Application date	January 23, 2025

ADAMS Accession No.	ML25023A218
Location in Application of NSHC	Pages 6 - 8 of Enclosure 2
Brief Description of Amendments	The proposed amendments would remove the unit staff qualification requirements from the respective plant Technical Specifications 5.3.1, and relocate control of the unit staff qualification requirements to the Quality Assurance Topical Report for Hatch, Units 1 and 2, Farley, Units 1 and 2, and Vogtle, Units 1 and 2, and Nuclear Development Quality Assurance Manual for Vogtle, Units 3 and 4, consistent with the guidance in NRC Administrative Letter 95-06, "Relocation of Technical Specification Administrative Controls related to Quality Assurance," dated December 12, 1995.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Millicent Ronnlund, Vice President and General Counsel, Southern Nuclear Operating Co., Inc., P. O. Box 1295, Birmingham, AL 35201-1295
NRC Project Manager, Telephone Number	John Lamb, 301-415-3100
Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 3 and 4; Burke County, GA	
Docket Nos.	52-025, 52-026
Application date	January 23, 2025
ADAMS Accession No.	ML25023A275
Location in Application of NSHC	Pages E-32 - E-33 of the Enclosure
Brief Description of Amendments	The proposed amendments would revise a number of technical specification-required actions applicable in shutdown (Operational Modes 5 and 6) as described in their letter dated January 23, 2025.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Millicent Ronnlund, Vice President and General Counsel, Southern Nuclear Operating Co., Inc., P. O. Box 1295, Birmingham, AL 35201-1295
NRC Project Manager, Telephone Number	G. Ed Miller, 301-415-2481
Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 3 and 4; Burke County, GA	
Docket Nos.	52-025, 52-026
Application date	July 25, 2024
ADAMS Accession No.	ML24207A252
Location in Application of NSHC	Pages E-7 - E-9 of the Enclosure
Brief Description of Amendments	The proposed amendments would revise Technical Specification (TS) 3.7.6, "Main Control Room Emergency Habitability System (VES)," Action A and Surveillance Requirement 3.7.6.6 related to inoperable valves and/or dampers.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Millicent Ronnlund, Vice President and General Counsel, Southern Nuclear Operating Co., Inc., P. O. Box 1295, Birmingham, AL 35201-1295

NRC Project Manager, Telephone Number	John Lamb, 301-415-3100
Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 3 and 4; Burke County, GA	
Docket Nos.	52-025, 52-026
Application date	January 24, 2025
ADAMS Accession No.	ML25024A238
Location in Application of NSHC	Pages E-13 - E-14 of the Enclosure
Brief Description of Amendments	The proposed amendments would modify Vogtle, Units 3 and 4, Combined Operating License, Appendix A, Technical Specification (TS), 3.3.15, "Engineered Safety Feature Actuation System (ESFAS) Actuation Logic - Operating," and TS 3.3.16, "Engineered Safety Feature Actuation System (ESFAS) Actuation Logic - Shutdown," to move surveillance requirements to other limiting conditions for operation to more appropriately address the scope and the required actions for the various components as described in their letter dated January 24, 2025.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Millicent Ronnlund, Vice President and General Counsel, Southern Nuclear Operating Co., Inc., P. O. Box 1295, Birmingham, AL 35201-1295
NRC Project Manager, Telephone Number	Jack Minzer Bryant, 301-415-0610
Vistra Operations Company LLC; Comanche Peak Nuclear Power Plant, Unit Nos. 1 and 2; Somervell County, TX	
Docket Nos.	50-445, 50-446
Application date	December 16, 2024
ADAMS Accession No.	ML24351A232
Location in Application of NSHC	Pages 2 - 3 of the Enclosure
Brief Description of Amendments	The proposed amendments would modify the Comanche Peak Nuclear Power Plants, Units 1 and 2, technical specifications to adopt Technical Specifications Task Force (TSTF) Traveler TSTF-522, "Revise Ventilation System Surveillance Requirements to Operate for 10 hours per Month," which would revise the surveillance requirements for certain ventilations systems with heaters operating from 10 continuous hours to 15 continuous minutes.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Roland Backhaus, Senior Lead Counsel-Nuclear, Vistra Corp., 325 7th Street, NW, Suite 520, Washington, DC 20004
NRC Project Manager, Telephone Number	Dennis Galvin, 301-415-6256
Vistra Operations Company LLC; Comanche Peak Nuclear Power Plant, Unit Nos. 1 and 2; Somervell County, TX	
Docket Nos.	50-445, 50-446
Application date	December 16, 2024

ADAMS Accession No.	ML24351A234
Location in Application of NSHC	Pages 1 - 3 of the Enclosure
Brief Description of Amendments	The proposed amendments would modify technical specification requirements in Section 1.3 regarding Completion Times and Section 3.0 regarding Limiting Condition for Operation and Surveillance Requirement usage. These changes are consistent with the NRC-approved Technical Specifications Task Force (TSTF) Traveler TSTF-529, Revision 4, "Clarify Use and Application Rules."
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Roland Backhaus, Senior Lead Counsel-Nuclear, Vistra Corp., 325 7th Street, NW, Suite 520, Washington, DC 20004
NRC Project Manager, Telephone Number	Dennis Galvin, 301-415-6256

III. Notice of Issuance of Amendments to Facility Operating Licenses and Combined Licenses

During the period since publication of the last monthly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or combined license, as applicable, proposed NSHC determination, and opportunity for a hearing in connection with these actions, were published in the *Federal Register* as indicated in the safety evaluation for each amendment.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special

circumstances provision in 10 CFR 51.22(b) and has made a determination based on that assessment, it is so indicated in the safety evaluation for the amendment.

For further details with respect to each action, see the amendment and associated documents such as the Commission’s letter and safety evaluation, which may be obtained using the ADAMS accession numbers indicated in the following table. The safety evaluation will provide the ADAMS accession numbers for the application for amendment and the *Federal Register* citation for any environmental assessment. All of these items can be accessed as described in the “Obtaining Information and Submitting Comments” section of this document.

License Amendment Issuances

DTE Electric Company; Fermi, Unit 2; Monroe County, MI	
Docket No.	50-341
Amendment Date	February 18, 2025
ADAMS Accession No.	ML24358A237
Amendment No.	230
Brief Description of Amendment	The amendment approved revision to the Fermi-2 updated final safety analysis report, to allow the use of a risk-informed methodology to address the impact of potential debris sources from a postulated high-energy line break on the emergency core cooling system suppression pool strainer performance. The Fermi technical specifications are not affected by this amendment.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Florida Power & Light Company; Turkey Point Nuclear Generating Unit Nos. 3 and 4; Miami-Dade County, FL	
Docket Nos.	50-250, 50-251
Amendment Date	February 12, 2025
ADAMS Accession No.	ML25043A428
Amendment Nos.	301 (Unit 3) and 294 (Unit 4)
Brief Description of Amendments	The amendments revised the Turkey Point Nuclear Generating, Unit Nos. 3 and 4, licensing basis by incorporating advanced fuel features (i.e., AXIOM® cladding, ADOPT™ fuel pellets, and a PRIME™ fuel skeleton), extend technical specification (TS) surveillance intervals, modify TS allowable values, apply an updated instrument channel setpoint uncertainty evaluation methodology, and make conforming changes to the

	Updated Final Safety Analysis Report to facilitate a transition to 24-month fuel cycles.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Tennessee Valley Authority; Sequoyah Nuclear Plant, Units 1 and 2; Hamilton County, TN	
Docket Nos.	50-327, 50-328
Amendment Date	February 3, 2025
ADAMS Accession No.	ML24345A104
Amendment Nos.	369 (Unit 1) and 363 (Unit 2)
Brief Description of Amendments	The amendments revised the Sequoyah Nuclear Plant, Units 1 and 2, Technical Specification (TS) 3.8.1, "AC [alternating current] Sources—Operating," to delete Surveillance Requirement (SR) 3.8.1.8, and revised TS 3.8.2, "AC Sources—Shutdown," to delete the reference to SR 3.8.1.8.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Union Electric Company; Callaway Plant, Unit No. 1; Callaway County, MO	
Docket No.	50-483
Amendment Date	February 13, 2025
ADAMS Accession No.	ML24362A040
Amendment No.	238
Brief Description of Amendment	The amendment revised the Callaway Plant, Unit No. 1, technical specifications (TSs) to adopt Technical Specifications Task Force (TSTF) Traveler TSTF- 569, Revision 2, "Revise Response Time Testing Definition." The amendment revised the TS definitions in Callaway TS section 1.1 for "ENGINEERED SAFETY FEATURE (ESF) RESPONSE TIME" and "REACTOR TRIP SYSTEM (RTS) RESPONSE TIME" that are referenced in surveillance requirements.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Wolf Creek Nuclear Operating Corporation; Wolf Creek Generating Station, Unit 1; Coffey County, KS	
Docket No.	50-482
Amendment Date	February 25, 2025
ADAMS Accession No.	ML24347A243
Amendment No.	242
Brief Description of Amendment	The amendment modified the implementation date of License Amendment No. 239 for the Wolf Creek Generating Station, Unit 1, for the use of portable lighting in the fire protection program.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Wolf Creek Nuclear Operating Corporation; Wolf Creek Generating Station, Unit 1; Coffey County, KS	

Docket No.	50-482
Amendment Date	February 26, 2025
ADAMS Accession No.	ML25043A149
Amendment No.	243
Brief Description of Amendment	The amendment revised the technical specification definitions for engineered safety feature response time and reactor trip system response time to adopt Technical Specifications Task Force (TSTF) Traveler TSTF-569, Revision 2, "Revise Response Time Testing Definition."
Public Comments Received as to Proposed NSHC (Yes/No)	No

Dated: March 13, 2025.

For the Nuclear Regulatory Commission.

Jamie Pelton,
Acting Director,
Division of Operating Reactor Licensing,
Office of Nuclear Reactor Regulation.

[FR Doc. 2025-04403 Filed: 3/17/2025 8:45 am; Publication Date: 3/18/2025]