



NUCLEAR REGULATORY COMMISSION

[NRC-2025-0214]

Monthly Notice; Applications and Amendments to Facility Operating Licenses and Combined Licenses Involving No Significant Hazards Considerations

AGENCY: Nuclear Regulatory Commission.

ACTION: Monthly notice.

SUMMARY: Pursuant to section 189a.(2) of the Atomic Energy Act of 1954, as amended (the Act), the U.S. Nuclear Regulatory Commission (NRC) is publishing this regular monthly notice. The Act requires the Commission to publish notice of any amendments issued, or proposed to be issued, and grants the Commission the authority to issue and make immediately effective any amendment to an operating license or combined license, as applicable, upon a determination by the Commission that such amendment involves no significant hazards consideration (NSHC), notwithstanding the pendency before the Commission of a request for a hearing from any person.

DATES: Comments must be filed by **[INSERT DATE 30 DAYS AFTER DATE OF PUBLICATION IN THE *FEDERAL REGISTER*]**. A request for a hearing or petitions for leave to intervene must be filed by **[INSERT DATE 60 DAYS AFTER DATE OF PUBLICATION IN THE *FEDERAL REGISTER*]**. This monthly notice includes all amendments issued, or proposed to be issued, from May 23, 2025, to June 18, 2025.

The last monthly notice was published on June 10, 2025.

ADDRESSES: You may submit comments by any of the following methods however, the NRC encourages electronic comment submission through the **Federal rulemaking website**.

- **Federal rulemaking website:** Go to <https://www.regulations.gov> and search for Docket ID **NRC-2025-0214**. Address questions about Docket IDs in Regulations.gov to Bridget Curran; telephone: 301-415-1003; email: Bridget.Curran@nrc.gov. For

technical questions, contact the individual listed in the “For Further Information Contact” section of this document.

- **Mail comments to:** Office of Administration, Mail Stop: TWFN-7-A60M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, ATTN: Program Management, Announcements and Editing Staff.

For additional direction on obtaining information and submitting comments, see “Obtaining Information and Submitting Comments” in the SUPPLEMENTARY INFORMATION section of this document.

FOR FURTHER INFORMATION CONTACT: Kathleen Entz, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-2464; email: Kathleen.Entz@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID **NRC 2025-0214**, facility name, unit number(s), docket number(s), application date, and subject when contacting the NRC about the availability of information for this action. You may obtain publicly available information related to this action by any of the following methods:

- **Federal Rulemaking Website:** Go to <https://www.regulations.gov> and search for Docket ID **NRC 2025-0214**.

- **NRC’s Agencywide Documents Access and Management System (ADAMS):** You may obtain publicly available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1-800-397-4209, at 301-415-4737, or by email to PDR.Resource@nrc.gov. For the convenience of the reader, instructions about obtaining materials referenced in this document are provided in the “Availability of Documents” section.

- **NRC's PDR:** The PDR, where you may examine and order copies of publicly available documents, is open by appointment. To make an appointment to visit the PDR, please send an email to PDR.Resource@nrc.gov or call 1-800-397-4209 or 301-415-4737, between 8 a.m. and 4 p.m. eastern time (ET), Monday through Friday, except Federal holidays.

B. Submitting Comments

The NRC encourages electronic comment submission through the **Federal rulemaking website** (<https://www.regulations.gov>). Please include Docket ID **NRC-2025-0214**, facility name, unit number(s), docket number(s), application date, and subject, in your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <https://www.regulations.gov> as well as enter the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. **Notice of Consideration of Issuance of Amendments to Facility Operating Licenses and Combined Licenses and Proposed No Significant Hazards Consideration Determination**

For the facility-specific amendment requests shown in this notice, the Commission finds that the licensees' analyses provided, consistent with section 50.91 of title 10 of *the Code of Federal Regulations* (10 CFR) "Notice for public comment; State consultation," are sufficient to support the proposed determinations that these

amendment requests involve NSHC. Under the Commission's regulations in 10 CFR 50.92, operation of the facilities in accordance with the proposed amendments would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety.

The Commission is seeking public comments on these proposed determinations. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determinations.

Normally, the Commission will not issue the amendments until the expiration of 60 days after the date of publication of this notice. The Commission may issue any of these license amendments before the expiration of the 60-day period, provided that its final determination is that the amendment involves NSHC. In addition, the Commission may issue any of these amendments prior to the expiration of the 30-day comment period if circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility. If the Commission takes action on any of these amendments prior to the expiration of either the comment period or the notice period, it will publish in the *Federal Register* a notice of issuance. If the Commission makes a final NSHC determination for any of these amendments, any hearing will take place after issuance. The Commission expects that the need to take action on any amendment before 60 days have elapsed will occur very infrequently.

A. Opportunity to Request a Hearing and Petition for Leave to Intervene

Within 60 days after the date of publication of this notice, any person (petitioner) whose interest may be affected by any of these actions may file a request for a hearing and petition for leave to intervene (petition) with respect to that action. Petitions shall be filed in accordance with the Commission's "Agency Rules of Practice and Procedure" in 10 CFR part 2. Interested persons should consult a current copy of 10 CFR 2.309. If a

petition is filed, the Commission or a presiding officer will rule on the petition and, if appropriate, a notice of a hearing will be issued.

Petitions must be filed no later than 60 days from the date of publication of this notice in accordance with the filing instructions in the “Electronic Submissions (E-Filing)” section of this document. Petitions and motions for leave to file new or amended contentions that are filed after the deadline will not be entertained, absent a determination by the presiding officer that the filing demonstrates good cause by satisfying the three factors in 10 CFR 2.309(c)(1)(i) through (iii).

If a hearing is requested and the Commission has not made a final determination on the issue of no significant hazards consideration, the Commission will make a final determination on the issue of no significant hazards considerations, which will serve to establish when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, then any hearing held would take place before the issuance of the amendment unless the Commission finds an imminent danger to the health or safety of the public, in which case it will issue an appropriate order or rule under 10 CFR part 2.

A State, local governmental body, Federally recognized Indian Tribe, or designated agency thereof, may submit a petition to the Commission to participate as a party under 10 CFR 2.309(h) no later than 60 days from the date of publication of this notice. Alternatively, a State, local governmental body, Federally recognized Indian Tribe, or agency thereof may participate as a non-party under 10 CFR 2.315(c).

For information about filing a petition and about participation by a person, not a party, under 10 CFR 2.315, see ADAMS Accession No. ML20340A053 (<https://adamswebsearch2.nrc.gov/webSearch2/main.jsp?AccessionNumber=ML20340A053>) and on the NRC’s public website at

<https://www.nrc.gov/about-nrc/regulatory/adjudicatory/hearing.html#participate>.

B. Electronic Submissions (E-Filing)

All documents filed in NRC adjudicatory proceedings, including documents filed by an interested State, local governmental body, Federally recognized Indian Tribe, or designated agency thereof that requests to participate under 10 CFR 2.315(c), must be filed in accordance with 10 CFR 2.302. The E-Filing process requires participants to submit and serve all adjudicatory documents over the internet, or in some cases, to mail copies on electronic storage media, unless an exemption permitting an alternative filing method, as further discussed, is granted. Detailed guidance on electronic submissions is located in the “Guidance for Electronic Submissions to the NRC” (ADAMS Accession No. ML13031A056) and on the NRC’s public website at <https://www.nrc.gov/site-help/e-submittals.html>.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by email at Hearing.Docket@nrc.gov, or by telephone at 301-415-1677, to (1) request a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign submissions and access the E-Filing system for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a petition or other adjudicatory document (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC’s public website at <https://www.nrc.gov/site-help/e-submittals/getting-started.html>. After a digital ID certificate is obtained and a docket created, the participant must submit adjudicatory documents in Portable Document Format. Guidance on submissions is available on the NRC’s public website at <https://www.nrc.gov/site-help/electronic-sub-ref-mat.html>. A filing is considered complete at the time the document is submitted through

the NRC's E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. ET on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an email confirming receipt of the document. The E-Filing system also distributes an email that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the document on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before adjudicatory documents are filed to obtain access to the documents via the E-Filing system.

A person filing electronically using the NRC's adjudicatory E-Filing system may seek assistance by contacting the NRC's Electronic Filing Help Desk through the "Contact Us" link located on the NRC's public website at <https://www.nrc.gov/site-help/e-submittals.html>, by email to MSHD.Resource@nrc.gov, or by a toll-free call at 1-866-672-7640. The NRC Electronic Filing Help Desk is available between 9 a.m. and 6 p.m., ET, Monday through Friday, except Federal holidays.

Participants who believe that they have good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing stating why there is good cause for not filing electronically and requesting authorization to continue to submit documents in paper format. Such filings must be submitted in accordance with 10 CFR 2.302(b)-(d). Participants filing adjudicatory documents in this manner are responsible for serving their documents on all other participants. Participants granted an exemption under 10 CFR 2.302(g)(2) must still meet the electronic formatting requirement in 10 CFR 2.302(g)(1), unless the participant also seeks and is granted an exemption from 10 CFR 2.302(g)(1).

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket, which is publicly available at <https://adams.nrc.gov/ehd>, unless excluded pursuant to an order of the presiding officer. If you do not have an

NRC-issued digital ID certificate as previously described, click “cancel” when the link requests certificates and you will be automatically directed to the NRC’s electronic hearing docket where you will be able to access any publicly available documents in a particular hearing docket. Participants are requested not to include personal privacy information such as social security numbers, home addresses, or personal phone numbers in their filings unless an NRC regulation or other law requires submission of such information. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants should not include copyrighted materials in their submission.

The following table provides the plant name, docket number, date of application, ADAMS accession number, and location in the application of the licensees’ proposed NSHC determinations. For further details with respect to these license amendment applications, see the applications for amendment, which are available for public inspection in ADAMS. For additional direction on accessing information related to this document, see the “Obtaining Information and Submitting Comments” section of this document.

License Amendment Requests

Constellation Energy Generation, LLC; Dresden Nuclear Power Station, Unit 1, Grundy County, IL	
Docket No.	50-010
Application Date	March 17, 2025
ADAMS Accession No.	ML25076A562
Location in Application of NSHC	Pages 3 - 4 of Attachment 1
Brief Description of Amendment	The proposed amendment would modify Technical Specifications (TS) 5.1.A, “Site and Exclusion Area,” for Dresden Nuclear Power Station (Dresden), Unit 1, to align with Dresden, Units 2 and 3, TS 4.1.1, “Site and Exclusion Area Boundaries,” and removes the specific acreage value. All three units share the same exclusion area. Removing the specific acreage value does not change the site area boundary or exclusion area but prevents the need for future amendments if the site acreage calculation changes with no change in boundary.
Proposed Determination	NSHC

Name of Attorney for Licensee, Mailing Address	Jason Zorn, Associate General Counsel, Constellation Energy Generation, LLC 4300 Winfield Road Warrenville, IL 60555
NRC Project Manager, Telephone Number	Tanya Hood, 301-415-1387
Entergy Louisiana, LLC, and Entergy Operations, Inc.; River Bend Station, Unit 1; West Feliciana Parish, LA; Entergy Operations, Inc., System Energy Resources, Inc., Cooperative Energy, A Mississippi Electric Cooperative, and Entergy Mississippi, LLC; Grand Gulf Nuclear Station, Unit 1; Claiborne County, MS; Entergy Operations, Inc.; Arkansas Nuclear One, Units 1 and 2; Pope County, AR; Entergy Operations, Inc.; Waterford Steam Electric Station, Unit 3; St. Charles Parish, LA	
Docket Nos.	50-313, 50-368, 50-382, 50-416, 50-458
Application Date	April 29, 2025
ADAMS Accession No.	ML25119A223
Location in Application of NSHC	Pages 21-23 of the Enclosure
Brief Description of Amendments	The proposed amendments would revise the technical specifications (TSs) for Arkansas Nuclear One, Units 1 and 2; Grand Gulf Nuclear Station, Unit 1; River Bend Station, Unit 1; and Waterford Steam Electric Station, Unit 3 (Waterford 3). Specifically, the proposed amendments would adopt Technical Specifications Task Force (TSTF) Traveler TSTF-596, "Expand the Applicability of the Surveillance Frequency Control Program (SFCP)," Revision 2, which is an approved change to the Standard Technical Specifications. TSTF-596, Revision 2, expands the applicability of the SFCP to include other periodic testing frequencies in TSs. The proposed amendments also would revise the SFCP to reference additional regulatory mechanisms that may be used to control surveillance frequencies, such as 10 CFR 50.55a and 10 CFR 50.69. The proposed amendments also revise surveillance requirements that reference the Inservice Testing Program to instead reference the SFCP. Additionally, a Ventilation Filter Testing Program, which is included in Revision 0 of NUREG 1432, "Standard Technical Specifications – Combustion Engineering Plants," would be added into the Waterford 3 TSs.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Susan Raimo, Associate General Counsel, Nuclear, 101 Constitution Avenue, NW, Washington, DC 20001
NRC Project Manager, Telephone Number	Michael Mahoney, 301-415-3867
Holtec Decommissioning International, LLC; Oyster Creek Nuclear Generating Station; Forked River, NJ	
Docket No.	50-219
Application Dates	August 1, 2024, as supplemented by letters dated March 27, 2025, April 29, 2025, May 13, 2025

ADAMS Accession Nos.	ML24214A037, ML25086A156, ML25119A267 (Package), ML25133A131
Location in Application of NSHC	Section 5.2. of Enclosure 1 (ML24214A037)
Brief Description of Amendment	The proposed amendment would incorporate the Oyster Creek Nuclear Generating Station's License Termination Plan (LTP). The LTP is a comprehensive plan outlining how the site will be decommissioned and how the residual radioactivity will be addressed to meet the criteria for unrestricted use and upon approval, would become a supplement to the Oyster Creek Nuclear Generating Station's Final Safety Analysis Report.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Erin Connolly, Corporate Counsel - Legal, Holtec International, Krishna P. Singh Technology Campus, 1 Holtec Blvd., Camden, NJ 08104
NRC Project Manager, Telephone Number	Amy Snyder, 301-415-6822
NextEra Energy Seabrook, LLC; Seabrook Station, Unit 1; Rockingham County, NH	
Docket No.	50-443
Application Date	May 12, 2025
ADAMS Accession No.	ML25132A013
Location in Application of NSHC	Pages 7-8 of the Enclosure
Brief Description of Amendment	The proposed license amendment would change the Emergency Action Levels for Initiating Condition HU4 in procedure ER 1.1, "Classification of Emergencies" procedure due to implementation of a new fire detection system inside the Seabrook Containment Building.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Steven Hamrick, Senior Attorney, 801 Pennsylvania Ave., NW, Suite 220 Washington, D.C. 20004
NRC Project Manager, Telephone Number	Ricardo Lantigua, 301-415-5107
R. E. Ginna Nuclear Power Plant, LLC and Constellation Energy Generation, LLC; R. E. Ginna Nuclear Power Plant; Wayne County, NY	
Docket No.	50-244
Application Date	May 20, 2025
ADAMS Accession No.	ML25140A128
Location in Application of NSHC	Section 4.2 of Attachment 1
Brief Description of Amendment	The proposed license amendment change would extend the Completion Time for Technical Specification 3.6.6 "Containment Spray (CS), Containment Recirculation Fan Cooler (CRFC), and NaOH Systems," the required Action B Sodium Hydroxide (NaOH) system inoperable. Specifically, the proposed change extends the Required Action B Completion Time to Restore NaOH System to OPERABLE status from 72 hours to 14 days.

Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Jason Zorn, Associate General Counsel, Constellation Energy Generation, LLC, 101 Constitution Ave, NW, Suite 400 East, Washington, DC 20001
NRC Project Manager, Telephone Number	V. Sreenivas, 301-415-2597
Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 1 and 2; Burke County, GA	
Docket Nos.	50-424, 50-425
Application Date	May 12, 2025
ADAMS Accession No.	ML25132A313
Location in Application of NSHC	Pages E-21 to E-23 of the Enclosure
Brief Description of Amendment	The proposed license amendment requests would revise the Vogtle Electric Generating Plant, Units 1 and 2, licensing basis to support a full scope application of an Alternate Source Term methodology following the guidance in Regulatory Guide 1.183, Revision 1.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Millicent Ronnlund, Vice President and General Counsel, Southern Nuclear Operating Co., Inc., P.O. Box 1295, Birmingham, AL 35201-1295
NRC Project Manager, Telephone Number	Jack Minzer Bryant, 301-415-0610
Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 3 and 4; Burke County, GA	
Docket Nos.	52-025, 52-026
Application Date	May 22, 2025
ADAMS Accession No.	ML25142A172
Location in Application of NSHC	Pages E-4 and E-5 of the Enclosure
Brief Description of Amendment	The proposed license amendment requests would change the technical specifications to include "nominal" to clarify requirements for spent fuel assembly initial enrichment.
Proposed Determination	NSHC
Name of Attorney for Licensee, Mailing Address	Millicent Ronnlund, Vice President and General Counsel, Southern Nuclear Operating Co., Inc., P.O. Box 1295, Birmingham, AL 35201-1295
NRC Project Manager, Telephone Number	John Lamb, 301-415-3100

III. Notice of Issuance of Amendments to Facility Operating Licenses and Combined Licenses

During the period since publication of the last monthly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application complies with the standards and requirements of

the Atomic Energy Act of 1954, as amended (the Act), and the Commission’s rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission’s rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or combined license, as applicable, proposed NSHC determination, and opportunity for a hearing in connection with these actions, were published in the *Federal Register* as indicated in the safety evaluation for each amendment.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.22(b) and has made a determination based on that assessment, it is so indicated in the safety evaluation for the amendment.

For further details with respect to each action, see the amendment and associated documents such as the Commission’s letter and safety evaluation, which may be obtained using the ADAMS accession numbers indicated in the following table. The safety evaluation will provide the ADAMS accession numbers for the application for amendment and the *Federal Register* citation for any environmental assessment. All of these items can be accessed as described in the “Obtaining Information and Submitting Comments” section of this document.

License Amendment Issuances

Arizona Public Service Company, et al; Palo Verde Nuclear Generating Station, Units 1, 2, and 3; Maricopa County, AZ	
Docket Nos.	50-528, 50-529, 50-530
Amendment Date	May 30, 2025
ADAMS Accession No.	ML25126A076
Amendment Nos.	225 (Unit 1), 225 (Unit 2), 225 (Unit 3)
Brief Description of Amendments	The amendments modified Technical Specification (TS) Section 3.5.1, “Safety

	Injection Tanks (SITs) - Operating,” and TS Section 3.5.2, “Safety Injection Tanks (SITs) - Shutdown,” and their bases. In addition, the amendments included the use of Generation of Thermal Hydraulic Information for Containments code as part of the methodology to perform calculations of the containment pressure and temperature response to the postulated pipe breaks.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Duke Energy Carolinas, LLC; Catawba Nuclear Station, Unit Nos. 1 and 2; York County, SC; Duke Energy Progress, LLC; H. B. Robinson Steam Electric Plant, Unit No. 2; Darlington County, SC; Duke Energy Progress, LLC; Shearon Harris Nuclear Power Plant, Unit 1; Wake and Chatham Counties, NC	
Docket Nos.	50-413, 50-414, 50-261, 50-400
Amendment Date	June 2, 2025
ADAMS Accession No.	ML25086A296
Amendment Nos.	321 (Catawba, Unit No. 1), 317 (Catawba, Unit No. 2), 203 (Harris), 281 (Robinson)
Brief Description of Amendments	The amendments revised technical specifications (TS) for Catawba Nuclear Station, Units 1 and 2 (CNS); Shearon Harris Nuclear Power Plant, Unit No. 1 (HNP); and H. B. Robinson Steam Electric Plant, Unit No. 2 (RNP), to Adopt Technical Specifications Task Force (TSTF) Traveler TSTF-234-A, Revision 1, “Add Action for More Than One DRPI [Digital Rod Position Indication] Inoperable.” The amendments also modified CNS TS 3.1.7, “Rod Position Indication,” RNP TS 3.1.7, “Rod Position Indication,” and HNP TS 3.1.3.2, “Position Indication Systems – Operating,” to add a Condition (Action for HNP) for more than one inoperable rod position indication per group. For CNS and RNP only, the amendments also modified the Action Note and provided clarification to the existing Required Actions A.1 and B.1.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Northern States Power Company; Prairie Island Nuclear Generating Plant, Units 1 and 2; Goodhue County, MN	
Docket Nos.	50-282, 50-306
Amendment Date	June 9, 2025
ADAMS Accession No.	ML25111A239
Amendment Nos.	247 (Unit 1), 235 (Unit 2)
Brief Description of Amendments	The amendments revised the technical specification (TS) definition of reactor trip system (RTS) response time to allow allocation of response times in lieu of testing using methodologies proposed in

	the license amendment request and revises applicability of Surveillance Requirement 3.3.1.16 to RTS trip functions in TS Table 3.3.1-1.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Pacific Gas and Electric Company; Diablo Canyon Nuclear Power Plant, Units 1 and 2; San Luis Obispo County, CA	
Docket Nos.	50-275, 50-323
Amendment Date	May 28, 2025
ADAMS Accession No.	ML25098A308
Amendment Nos.	250 (Unit 1), 252 (Unit 2)
Brief Description of Amendments	The amendments revised technical specifications to adopt Technical Specifications Task Force (TSTF) Traveler TSTF-541, "Add Exceptions to Surveillance Requirements for Valves and Dampers Locked in the Actuated Position," which is an approved change to the Standard Technical Specifications.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Southern Nuclear Operating Company, Inc.; Vogtle Electric Generating Plant, Units 3 and 4; Burke County, GA	
Docket Nos.	52-025, 52-026
Amendment Date	May 30, 2025
ADAMS Accession No.	ML25122A101
Amendment Nos.	201 (Unit 3), 198 (Unit 4)
Brief Description of Amendments	The amendments revised the technical specifications (TSs) to adopt Technical Specifications Task Force (TSTF) Traveler TSTF-554, "Revise Reactor Coolant Leakage Requirements," for the Vogtle Electric Generating Plant, Units 3 and 4. The amendments revised the TS definition of "Leakage," clarified the requirements when pressure boundary leakage is detected, and added a Required Action when pressure boundary leakage is identified.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Tennessee Valley Authority; Browns Ferry Nuclear Plant, Units 1, 2, and 3; Limestone County, AL	
Docket Nos.	50-259, 50-260, 50-296
Amendment Date	May 27, 2025
ADAMS Accession No.	ML25093A254
Amendment Nos.	335 (Unit 1), 358 (Unit 2), 318 (Unit 3)
Brief Description of Amendments	The amendments revised the Browns Ferry Nuclear Plant, Units 1, 2, and 3, Technical Specification (TS) 3.4.3, "Overpressure Protection System (OPS)," and TS 5.6.5,

	“Core Operating Limits Report (COLR),” to reflect the adoption of Technical Specifications Task Force (TSTF) Traveler TSTF-576, Revision 3, “Revise Safety/Relief Valve Requirements.”
Public Comments Received as to Proposed NSHC (Yes/No)	No
Vistra Operations Company LLC; Comanche Peak Nuclear Power Plant, Unit Nos. 1 and 2; Somervell County, TX	
Docket Nos.	50-445, 50-446
Amendment Date	May 22, 2025
ADAMS Accession No.	ML25121A142
Amendment Nos.	191 (Unit 1), 191 (Unit 2)
Brief Description of Amendments	The amendments modified the Comanche Peak Nuclear Power Plant, Unit Nos. 1 and 2, technical specifications to adopt Technical Specifications Task Force (TSTF) Traveler TSTF-522, Revision 0, to revise the surveillance requirements for certain ventilations systems with heaters operating from 10 continuous hours to 15 continuous minutes.
Public Comments Received as to Proposed NSHC (Yes/No)	No
Wolf Creek Nuclear Operating Corporation; Wolf Creek Generating Station, Unit 1; Coffey County, KS	
Docket No.	50-482
Amendment Date	June 12, 2025
ADAMS Accession No.	ML25100A116
Amendment No.	244
Brief Description of Amendment	The amendment revised Technical Specification 3.2.1, “Heat Flux Hot Channel Factor ($F_Q(Z)$) (F_Q Methodology),” to implement the methodology in Pressurized Water Reactor Owners Group Topical Report WCAP-17661-P-A, Revision 1, “Improved RAOC [Relaxed Axial Offset Control] and CAOC [Constant Axial Offset Control] F_Q Surveillance Technical Specifications.”
Public Comments Received as to Proposed NSHC (Yes/No)	No

Dated: June 30, 2025.

For the Nuclear Regulatory Commission.

Jamie Pelton,

Director,

Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2025-12367 Filed: 7/7/2025 8:45 am; Publication Date: 7/8/2025]