



NUCLEAR REGULATORY COMMISSION

[Docket No. 50-318; NRC-2025-1700]

Constellation Energy Generation, LLC;

Calvert Cliffs Nuclear Power Plant, Unit 2;

License Amendment Request

AGENCY: Nuclear Regulatory Commission.

ACTION: Opportunity to comment, request a hearing and to petition for leave to intervene.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an amendment to Renewed Facility Operating License (RFOL) No. DPR-69, issued to Constellation Energy Generation, LLC (CEG, the licensee) for Calvert Cliffs Nuclear Power Plant, Unit 2 (CCNPP). The proposed license amendment would extend the completion time (CT) for Technical Specification 3.8.1, "AC [alternating current] Sources-Operating," Action D.3. For this amendment request, the NRC proposes to determine that it involves no significant hazards consideration.

DATES: Submit comments by **[INSERT DATE 30 DAYS AFTER DATE OF PUBLICATION IN THE *FEDERAL REGISTER*]**. Comments received after this date will be considered if it is practical to do so, but the NRC is able to ensure consideration only for comments received on or before this date. Requests for a hearing or petition for leave to intervene must be filed by **[INSERT DATE 60 DAYS AFTER DATE OF PUBLICATION IN THE *FEDERAL REGISTER*]**.

ADDRESSES: You may submit comments by any of the following methods however, the NRC encourages electronic comment submission through the **Federal rulemaking website**.

- **Federal rulemaking website:** Go to <https://www.regulations.gov> and search for Docket ID **NRC-2025-1700**. Address questions about Docket IDs in [Regulations.gov](https://www.regulations.gov)

to Bridget Curran; telephone: 301-415-1003; email: Bridget.Curran@nrc.gov. For technical questions, contact the individual(s) listed in the “For Further Information Contact” section of this document.

- **Mail comments to:** Office of Administration, Mail Stop: TWFN-7-A60M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, ATTN: Program Management, Announcements and Editing Staff.

For additional direction on obtaining information and submitting comments, see “Obtaining Information and Submitting Comments” in the SUPPLEMENTARY INFORMATION section of this document.

FOR FURTHER INFORMATION CONTACT: Sam Bina, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-3425; email: Samuel.Bina@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID **NRC-2025-1700** when contacting the NRC about the availability of information for this action. You may obtain publicly available information related to this action by any of the following methods:

- **Federal Rulemaking Website:** Go to <https://www.regulations.gov> and search for Docket ID **NRC-2025-1700**.

- **NRC’s Agencywide Documents Access and Management System (ADAMS):** You may obtain publicly available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1-800-397-4209, at 301-415-4737, or by email to PDR.Resource@nrc.gov. The amendment request is available at ML25275A565.

- **NRC's PDR:** The PDR, where you may examine and order copies of publicly available documents, is open by appointment. To make an appointment to visit the PDR, please send an email to PDR.Resource@nrc.gov or call 1-800-397-4209 or 301-415-4737, between 8 a.m. and 4 p.m. eastern time (ET), Monday through Friday, except Federal holidays.

B. Submitting Comments

The NRC encourages electronic comment submission through the **Federal rulemaking website** (<https://www.regulations.gov>). Please include Docket ID **NRC-2025-1700** in your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <https://www.regulations.gov> as well as enter the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. Introduction

The NRC is considering issuance of an amendment to RFOL No. DPR-69 for Calvert Cliffs Nuclear Power Plant, Unit 2, located in Calvert, Maryland.

The amendment would allow a one-time extension of the CT for Technical Specification 3.8.1, Action D.3, as described in their submittal dated October 2, 2025.

Before issuance of the proposed license amendment, the NRC will need to make the findings required by the Atomic Energy Act of 1954, as amended (the Act), and NRC's regulations.

The NRC has made a proposed determination that the license amendment request involves no significant hazards consideration. Under the NRC's regulations in section 50.92 of title 10 of the *Code of Federal Regulations* (10 CFR), this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented as follows:

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed TS change will not increase the probability of an accident since it will only extend the time period that one qualified offsite circuit can be out of service. The extension of the time duration that one qualified offsite circuit is out of service has no direct physical impact on the plant. The proposed inoperable offsite circuit limits the available redundancy of the offsite electrical system to a period not to exceed 14 days for Unit 2. Therefore, the proposed TS change does not have a direct impact on the plant that would make an accident more likely to occur due to the extended completion time.

During transients or events which require these subsystems to be operating, there is sufficient capacity in the operable loops/subsystems and available but inoperable equipment to support plant operation or shutdown. Therefore, failures that are accident initiators will not occur more frequently than previously postulated as a result of the proposed change.

In addition, the consequences of an accident previously evaluated in the Updated Final Safety Analysis Report (UFSAR) will not be increased. With one offsite circuit inoperable, the consequences of any postulated accidents occurring during this CT

extension were found to be bounded by the previous analyses as described in the UFSAR.

The minimum equipment required to mitigate the consequences of an accident and/or safely shut down the plant will be operable or available. Therefore, by extending the CT and extending the assumptions concerning the combinations of events for the longer duration of the extended CT, CEG concludes that at least the minimum equipment required to mitigate the consequences of an accident and/or safely shut down the plant will still be operable or available.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed TS change will not create the possibility of a new or different type of accident since it will only extend the time period that one of the offsite circuits can be out of service. The extension of the time duration that one offsite circuit can be out of service has no direct physical impact on the plant and does not create any new accident initiators. The systems involved are accident mitigation systems. All of the possible impacts that the inoperable equipment may have on its supported systems were previously analyzed in the UFSAR and are the basis for the present TS Action statements and CTs. The impact of inoperable support systems for a given time duration was previously evaluated and any accident initiators created by the inoperable systems was evaluated. The lengthening of the time duration does not create any additional accident initiators for the plant.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No.

The present offsite circuit TS CT limits were set to ensure that sufficient safety-related equipment is available for response to all accident conditions and that sufficient decay heat removal capability is available for a loss-of-coolant accident (LOCA) coincident with a loss of offsite power (LOOP) on one unit and simultaneous safe shutdown of the other unit. A slight reduction in the margin of safety is incurred during the proposed extended CT due to the increased risk that an event could occur in a 14-day period versus a 72-hour period. This increased risk is judged to be minimal due to the low likelihood of an event occurring during the extended CT and maintaining the minimum ECCS/decay heat removal requirements.

The slight reduction in the margin of safety from the extension of one offsite circuit current CT limit is not significant since the remaining operable offsite circuit, the emergency diesel generators, the Station Blackout (SBO) Diesel, and the FLEX diesel generators provide an effective defense-in-depth plan to support the station electrical plant configurations during the extended CT period.

Operations personnel are fully qualified by normal periodic training to respond to, and mitigate, a Design Basis Accident, including the actions needed to ensure decay heat removal while CCNPP, Units 1 and 2 are in the operational electrical configurations described within this submittal. Accordingly, existing procedures are in place that address safe plant shutdown and decay heat removal for situations applicable to those in the proposed CTs. Therefore, the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the license amendment request involves no significant hazards consideration.

The NRC is seeking public comments on this proposed determination that the license amendment request involves no significant hazards consideration. Any

comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of 60 days after the date of publication of this notice. The Commission may issue the license amendment before expiration of the 60-day notice period if the Commission concludes the amendment involves no significant hazards consideration. In addition, the Commission may issue the amendment prior to the expiration of the 30-day comment period if circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility. If the Commission takes action prior to the expiration of either the comment period or the notice period, it will publish in the Federal Register a notice of issuance. If the Commission makes a final no significant hazards consideration determination, any hearing will take place after issuance. The Commission expects that the need to take this action will occur very infrequently.

III. Opportunity To Request a Hearing and Petition for Leave To Intervene

Within 60 days after the date of publication of this notice, any person (petitioner) whose interest may be affected by this action may file a request for a hearing and petition for leave to intervene (petition) with respect to the action. Petitions shall be filed in accordance with the Commission's "Agency Rules of Practice and Procedure" in 10 CFR part 2. Interested persons should consult 10 CFR 2.309. If a petition is filed, the presiding officer will rule on the petition and, if appropriate, a notice of a hearing will be issued.

Petitions must be filed no later than 60 days from the date of publication of this notice in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document. Petitions and motions for leave to file new or amended contentions that are filed after the deadline will not be entertained absent a determination by the presiding officer that the filing demonstrates good cause by satisfying the three factors in 10 CFR 2.309(c)(1)(i) through (iii).

If a hearing is requested and the Commission has not made a final determination on the issue of no significant hazards consideration, the Commission will make a final determination on the issue of no significant hazards consideration, which will serve to establish when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, then any hearing held would take place before the issuance of the amendment unless the Commission finds an imminent danger to the health or safety of the public, in which case it will issue an appropriate order or rule under 10 CFR part 2.

A State, local governmental body, Federally recognized Indian Tribe, or designated agency thereof, may submit a petition to the Commission to participate as a party under 10 CFR 2.309(h) no later than 60 days from the date of publication of this notice. Alternatively, a State, local governmental body, Federally recognized Indian Tribe, or agency thereof may participate as a non-party under 10 CFR 2.315(c).

For information about filing a petition and about participation by a person not a party under 10 CFR 2.315, see ADAMS Accession No. ML20340A053 (<https://adamswebsearch2.nrc.gov/webSearch2/main.jsp?AccessionNumber=ML20340A053>) and on the NRC's public website (<https://www.nrc.gov/about-nrc/regulatory/adjudicatory/hearing.html#participate>).

IV. Electronic Submissions and E-Filing

All documents filed in NRC adjudicatory proceedings, including documents filed by an interested State, local governmental body, Federally recognized Indian Tribe, or designated agency thereof that requests to participate under 10 CFR 2.315(c), must be filed in accordance with 10 CFR 2.302. The E-Filing process requires participants to submit and serve all adjudicatory documents over the internet, or in some cases, to mail copies on electronic storage media, unless an exemption permitting an alternative filing

method, as further discussed, is granted. Detailed guidance on electronic submissions is located in the “Guidance for Electronic Submissions to the NRC” (ADAMS Accession No. ML13031A056), and on the NRC’s public website (<https://www.nrc.gov/site-help/e-submittals.html>).

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by email at Hearing.Docket@nrc.gov, or by telephone at 301-415-1677, to: (1) request a digital identification (ID) certificate which allows the participant (or its counsel or representative) to digitally sign submissions and access the E-Filing system for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a petition or other adjudicatory document (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC’s public website at <https://www.nrc.gov/site-help/e-submittals/getting-started.html>. After a digital ID certificate is obtained and a docket is created, the participant must submit adjudicatory documents in the Portable Document Format. Guidance on submissions is available on the NRC’s public website at <https://www.nrc.gov/site-help/electronic-sub-ref-mat.html>. A filing is considered complete at the time the document is submitted through the NRC’s E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. ET on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an email confirming receipt of the document. The E-Filing system also distributes an email that provides access to the document to the NRC’s Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the document on those participants separately. Therefore, applicants and other participants (or their counsel or

representative) must apply for and receive a digital ID certificate before adjudicatory documents are filed in order to obtain access to the documents via the E-Filing system.

A person filing electronically using the NRC's adjudicatory E-Filing system may seek assistance by contacting the NRC's Electronic Filing Help Desk through the "Contact Us" link located on the NRC's public website at <https://www.nrc.gov/site-help/e-submittals.html>, by email to MSHD.Resource@nrc.gov, or by a toll-free call at 1-866-672-7640. The NRC Electronic Filing Help Desk is available between 9 a.m. and 6 p.m., ET, Monday through Friday, except Federal holidays.

Participants who believe that they have good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing stating why there is good cause for not filing electronically and requesting authorization to continue to submit documents in paper format. Such filings must be submitted in accordance with 10 CFR 2.302(b)-(d). Participants filing adjudicatory documents in this manner are responsible for serving their documents on all other participants. Participants granted an exemption under 10 CFR 2.302(g)(2) must still meet the electronic formatting requirement in 10 CFR 2.302(g)(1), unless the participant also seeks and is granted an exemption from 10 CFR 2.302(g)(1).

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket, which is publicly available at <https://adams.nrc.gov/ehd>, unless otherwise excluded pursuant to an order of the presiding officer. If you do not have an NRC-issued digital ID certificate as previously described, click "cancel" when the link requests certificates and you will be automatically directed to the NRC's electronic hearing docket where you will be able to access any publicly available documents in a particular hearing docket. Participants are requested not to include personal privacy information such as social security numbers, home addresses, or personal phone numbers in their filings unless an NRC regulation or other law requires submission of such information. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair

Use application, participants should not include copyrighted materials in their submission.

For further details with respect to this action, see the application for license amendment dated October 2, 2025 (ADAMS Accession No. ML25275A565).

Attorney for licensee: Jason Zorn, Associate General Counsel, Constellation Energy Generation, LLC 4300 Winfield Road, Warrenville, IL 60555.

NRC Branch Chief: Hipolito Gonzalez.

Dated: November 20, 2025.

For the Nuclear Regulatory Commission.

David Wrona, Chief,
Plant Licensing Branch II-2,
Division of Operating Reactor Licensing,
Office of Nuclear Reactor Regulation.

[FR Doc. 2025-20792 Filed: 11/21/2025 8:45 am; Publication Date: 11/24/2025]